

ADENDUM NO1 THURSDAY, 19TH OCTOBER 2023

IMPORTANT: Tenderers are required to acknowledge this tender addendum prior to the Tender Closing Date.

Acknowledgements must be sent via email to procurement@kdic.go.ke prior to the Closing Date of the tender

This addendum forms an integral part of the tender document and will therefore be considered at the evaluation stage. It contains specific tender document technical specifications that have been amended as a result of clarifications sort by writing to procurement@kdic.go.ke.

Further to Request to Tender REF. TENDER FOR PROVISION OF PREVENTIVE MAINTENANCE SERVICES FOR MODULAR DATA CENTER, AIR CONDITIONING & MECHANICAL VENTILATION SYSTEMS, AND CCTV CAMERAS: TENDER NO. KDIC/OT/11/2023-2024.

Tenderer are advised of the following clarification(s) to the tender documents.

Clarification(s):

- 1- Eaton 9E 40Kva 3pcs (from the document in page 62 you indicated that you have 3pcs Eaton 9E. The other two pieces are at KDIC go-down and KSMS site, which are also part of annual maintenance. The two sites can be accessed if need be, upon request.
- 3- VRF Outdoor Units (Carrier)(clarify on page 62 of the document where we have Carrier type 6 indoor units and 34 Carrier type outdoor units .
VRF outdoor units is 6 not 34. The 34 is the Toshiba ceiling mount air conditioners which need to be maintained as well
- 4 -Split Units 5pcs. Document mentions 5 pcs.
We have split units on 16th, 17th, 23rd, 24th and 25th floor
- 5- Triplite 40Kva 6pcs
We have one Triplite 40Kva and the rest 5 UPS are servo-Matic 10Kva not Triplite
- 7- We also have rack mount UPS (APC type) on the 12u (for CCTV and biometrics) cabinets which are not included in the document.
Not part of the scope
- 8-We have UPS (mercer type) in the 32u cabinet for users' data points which are not included in the document.
Not part of the scope
- 9-The document does not mention the Toshiba ceiling mount air conditioners in boardrooms and other offices.
This is also part of what is to be maintained.
- 10- Please also confirm if there will be a need for 1. Verification for Fire suppression
KDIC modular DC has inbuilt fire alarm system which is also protected with a fire suppression system. We need someone with expertise to check on the logs and advise us as well of the performance of the system

All other terms and conditions remain unchanged.

[End of Tender Addendum]